


REV	DATE	ALTERED	REV	DATE	ALTERED UKH -SD-	GMS No./ C.B.O.M.- NO. 01231301000	STATUS OF DRG U		
		CHECKED	03	11.01.06	CHECKED RCA -SD-				
ZONE			ZONE	THIS DRG. SUPERCEDES THE OLD DRG. UNDER THE SAME NO. WITHOUT ANY CHANGE AND DEPOSITED ON WRENCH. CHANGE ADVICE NO. STE-05-F0208.		AGREED DEPT	NAME	SIGN	DATE
GRADE OF UNTOL.DIM			M/CG. - AA0230208 m		WELDING-CLASS 'B' OF AA0621104	GAS CUTTING-TABLE 3 OF AA0621101			



NOTE:— THE SUPPLIER SHALL CARRY OUT THE FOLLOWING TESTS AND SHALL FURNISH THE TEST CERTIFICATES FOR THE SAME:—

1. DIELECTRIC STRENGTH, 500 VDC.
2. NULL VOLTAGE, NULL POSITION, SCALE FACTOR (SENSITIVITY), PHASING, LINEARITY, CALIBRATION FOR OUTPUT VOLTAGE V/S STROKE, RESPONSE TIME AND MEASURING TOLERANCE.

TECHNICAL REQUIREMENTS:—

1. THE POSITION TRANSDUCER SHALL BE OF TYPE SS207 OF COLLINS OR EQUIVALENT.
2. THREADS 2-56UNC-3B SHALL BE AS PER ASA B1.1-1960
A SUITING NUT SHALL BE SUPPLIED WITH THE REMOTE POSITION TRANSMITTER.
3. BHEL MATL. CODE : W97312313010.

COPYRIGHT AND CONFIDENTIAL

THE INFORMATION ON THIS DOCUMENT IS THE PROPERTY OF BHARAT HEAVY ELECTRICALS LIMITED. IT MUST NOT BE USED DIRECTLY OR INDIRECTLY IN ANY WAY DETERIMENTAL TO THE INTEREST OF THE COMPANY.

47109-0048
Ref.Drawing No>

Sign & Date



BHARAT HEAVY ELECTRICALS LTD.
RANIPUR, HARDWAR

	NAME	SIGN	DATE	NO. OF VAR —
DRN	D.SINGH	-sd-	22.10.80	
CHD	G.K.DIXIT	-sd-	23.10.80	
APPD	M.R.K	-sd-	28.4.81	—

Inventory No.	DEPT STE		SCALE	WEIGHT (KG)	REF. TO ASSY. DRG. 0-12313-02000 0-12313-01000 0-11421-01000	ITEM No.	NO. OF ITEMS —
	CODE 4011		NTS	0.15		126, 29	
TITLE : POSITION TRANSDUCER					CARD CODE	DRAWING NO. 4-12313-01039	
					7	22	23 24
					SHEET No. 01		No. OF SHEETS 01