



**BHARAT HEAVY ELECTRICALS  
LIMITED, BHOPAL**

**DOCUMENT NO.  
STE-Z6-176-01-R0**

**STEAM TURBINE ENGINEERING**

Dt: **18-Nov-2014**

Pg. No. **1 of 1**

This requirement is for the vendors who are manufacturing or supplying  
**Reinforced gasket with stainless steel.**

A) Item –

- 1) Item No. 1 – 1/16" GRAPHITE REINFORCED WITH TANG STAINLESS STEEL GASKET AS PER ASME B 16.21.
- 2) Item No. 2 – GRAPHITE GASKET WITH SS316 WIRE REINFORCEMENT, AS PER DRAWING 753D80794

B) Quantity –

- 1) Item No. 1 – 08 No.s
- 2) Item No. 2 – 40 No.s

C) Size of flange –

- 1) Item No. 1 – 12 inch Raised face Slip on Flange, DN 300, Class 300 (as per ASME B16.5)
- 2) Item No. 2 – 44 inch Raised face Slip on flange, Class 150 (as per BS3293)

Prepared By: Ankit Singh

Approved By: Dipak Bag