

BHEL | Technical Spec. of : RESISTOR | Page 1 of 1

Bhopal |

SWE | PI no.:240951337

| Enq. No:

| PO No:

W.O. Nos.:94020-A-47604 (MANUGURU)

VARIABLE DAMPING RESISTOR**ITEM 001:- VARIABLE DAMPING RESISTOR**

DAMPING RESISTOR WITH MOUNTING CLAMP AND HARDWARE REQUIRED FOR PT OPEN DELTA SECONDARY WINDING HAVING FOLLOWING DETAILS.

- | | |
|--|--------------------------------------|
| 1. RESISTANCE POWER(W) | :- 200W |
| 2. STANDARDISED RESISTANCE | :- 0-200 Ω |
| 3. MINIMUM COMPUTED RESISTANCE | :- 34.9 Ω |
| 4. RATED THERMAL BURDEN OF THE SECONDARY | :- 50-200VA |
| 5. RATED SECONDARY VOLTAGE | :- 110/3 V |
| 6. MOUNTING | :- BASE MOUNTING WITH MOUNTING CLAMP |

- NOTES :-**
- 1) 3 Copies of OGA drg. With mounting clamp to be furnished along with offer.
 - 2) 3 Copies of routine test certificates are to be furnished at the time of delivery.

ACCEPTANCE CRITERIA :-

- i) Visual checks for crack and surface finish.
- ii) Rating plate as per specification parameters.
- iii) Availability of all routine test certificates.

PREP BY :- RAHUL RAJPUT
DATE :- 09.11.2015

APPROVED BY : VAIBHAV DIXIT
DATE : 09.11.2015