


35216601996 ON DRG

THE INFORMATION ON THIS DOCUMENT IS THE PROPERTY OF BHARAT HEAVY ELECTRICALS LIMITED. IT MUST NOT BE USED DIRECTLY OR INDIRECTLY IN ANY WAY DETRIMENTAL TO THE INTEREST OF THE COMPANY.



STYLE NO :-
 VAR-00-BP 9049107230
 VAR-01-BP 9049107249
 VAR-02-BP 9049107257
 VAR-03-BP 9049107265
 VAR-04-BP 9049107273
 VAR-05-BP 9049107281
 VAR-06-BP 9049107290

- VAR.00- COMPLETE ASSY. OF FLEXIBLE CONNECTION SUITABLE FOR SURGE SUPPRESSOR MOUNTED IN C.T. CHAMBER.
- VAR.01- COMPLETE ASSY. OF FLEXIBLE CONNECTION SUITABLE FOR 3 EF1 SURGE ARRESTER MOUNTED ON VCB TRUCK
- VAR.02- COMPLETE ASSY. OF FLEXIBLE CONNECTION SUITABLE FOR V. T. CONNECTION.
- VAR.03- COMPLETE ASSY. OF FLEXIBLE CONNECTION OF SURGE SUPPRESSOR FOR BUS IN BPT PANEL
- VAR.04- COMPLETE ASSY. OF FLEXIBLE CONNECTION SUITABLE FOR P.T. ON FEB
- VAR.05- COMPLETE ASSY. OF FLEXIBLE CONNECTION SUITABLE FOR P.T. ON BPT/FPT
- VAR.06- COMPLETE ASSY. OF FLEXIBLE CONNECTION SUITABLE FOR P.T. ON BEB

VAR 06	VAR 05	VAR 04	VAR 03	VAR 02	VAR 01	VAR 00	REMARKS	VAR NO.	ITEM NO.	DESCRIPTION	UNIT	DRAWING NO.	IT.NO.	MATERIAL CODE	MATL. SPCN.	UNIT	UNIT WT.	QTY
									009	CJ CRIMPIN LUG (5.3 Ø)	KG							
									008	5.3 Ø X 820 Ig ETHY. PROP. RUBBER INSULATED CABLE VOLT GRD. 3300 V	KG			AA28542 SL.09				
							FOR BEB		007	5.3 Ø X 357 Ig ETHY. PROP. RUBBER INSULATED CABLE VOLT GRD. 3300 V	KG			AA28542 SL.09				
							FOR BPT/FPT		006	5.3 Ø X 257 Ig ETHY. PROP. RUBBER INSULATED CABLE VOLT GRD. 3300 V	KG			AA28542 SL.09				
							FOR FEB		005	CPR. CRIMPING TERMINAL (14.8 Ø)	KG							
									004	14.5 Ø X 290 Ig ETHY. PROP. RUBBER INSULATED CABLE VOLT GRD. 3300 V	KG			AA28542 SL.14				
									003	14.5 Ø X 395 Ig ETHY. PROP. RUBBER INSULATED CABLE VOLT GRD. 3300 V	KG			AA28542 SL.14				
									002	14.5 Ø X 381 Ig ETHY. PROP. RUBBER INSULATED CABLE VOLT GRD. 3300 V	KG			AA28542 SL.14				
									001	5.3 Ø X 200 Ig ETHY. PROP. RUBBER INSULATED CABLE VOLT GRD. 3300 V	KG			AA28542 SL.09				

NOTE:- 3300V GRADE INSULATED CONDUCTOR SHALL BE USED FOR ALL 3.3kv/6.6kv/11kv SYSYETM DUE TO SUFFICIENT AVAILABLE CLEARANCES.

ADDITIONAL INFORMATION		TYPE OF PRODUCT OR NAME OF CUST/PROJ		VM-12			
STATUS OF DRAWING		B					
DISTRIBUTION OF PRINTS		O/C ----1					
		SWM ---- 3					
		TCX ----1					
BHARAT HEAVY ELECTRICALS LIMITED BHOPAL		DRN	B.K.TOTAWAR	SIGN		DATE	
		CKD	P.SONKAR				
		APPD	J.S.PURIA				NO. OF VAR 07
REV 03	DATE 14.06.10	DRN CKD APPD		REV 02	DATE 21.05.10	DRN MANI CKD APPD	M.A.K.
SPEC WAS AA28542-SL14, FOR ITEM-001 STYLE NOS FOR VAR04 TO 06 WAS NOT ON (DCA NO. 29764)		-CABLE DIA OF ITEM 001 CHANGED TO 5.3. -VIEW FOR VAR. 02 DELETED -LENGTH OF CABLES FOR ITEMS 001,006, 007 & 008 WERE 220, 295, 450 & 820 RESPECTIVELY AND LUG CHANGED FOR V00. (DCA NO. 29764)		REV 01		DATE 08.03.10	DRN ANAND CKD AKHIL APPD M.A.K.
		- VAR. 04,05,06 ADDED - VAR. 02 DELETED - VOLT GRADE UPDATED & NOTE ADDED (DCA NO. 29629)					
DEPT SWE	UN. TOL.DIM.GR.	SCALE	WEIGHT (KG.)	REF TO ASSY	ITEM NO.	NO.OF ITEMS	
409	M 0230208	NTS		35216601525 35212001615 35216601996	012 005 003	009	
ASSY. OF FLEXIBLE CONNECTION.				DRG NO	35216601996		REV. 03
				SHT.NO.	01	NO.OF SHT.	01

KANSARA

35216601996-R01-S01 REF.DRG.NO.

SIGN. & DATE

INVENTORY NO.