




Annexure-A

Specification of item 001 – Current Testing Connectors

Sl.No	Parameter	Description
1	Size	2
2	Nominal Current(A)	800
3	Test Current (max) 4min./A	2500
4	Rated Short time withstand current 1s(kA)	40
5	Rated Short time withstand current 3s(kA)	25
6	Max. testing Voltage(kV)	2
7	Length	184mm

Specification of item 002 – Connex Test Cable

Sl.No	Parameter	Description
1	Size	2
2	Max. Operating Voltage (kV)	42
3	Rated power frequency withstand voltage 1min(kV)	95
4	Rated Lightning Impulse withstand voltage(kV)	200
5	Cable Cross Section (Sq.mm)	95
6	Rated Current (A)	440
7	Length of Test Cable(meter)	3
8	Length of Earth Connection(mm)	300



REV.	00	PRINTS TO:-		APPROVED –		
ALTD.	AK		1	HRP		
APPD.	HRP		1	PREPARED	ISSUED	DATE
DATE.	24.04.2014		1	AK	APS	24.04.2014