

TECHNICAL SPECIFICATION OF TERMINAL BLOCKS FOR AVR

ITEM-1: 48 Pin Euro card connector to the following specification

| Material code | BP9047581377 |
|----------------|---|
| Conductor Size | 0.02-4 mm ² (single core) or 0.02-2.5 mm ² (stranded) |
| Rated Voltage | 250 V AC |
| Rated Current | 4A |
| Configuration | 48 pin (EN60603-2) |
| Material | Plastic, Flame retardant |
| Mounting | suitable for mounting on 35mm din rail |
| Connection | Cage clamp/ Screw terminals |
| Termination | As shown in the schematic diagram below |


Dimensional drawing







Schematic diagram



| | Name | Signature | Specification no: CEE/14025 |
|-------------------------------------|------------------------------|-----------------|-----------------------------|
| Prepared & checked by Revised By | Shalini Sharma Ajay Dhote | Artini. Astinte | |
| Approved by | A Mitra | mile | Revision no: 01 |
| Date | 24.04.14 | | Date of revision: 12.05.15 |

TECHNICAL SPECIFICATION OF TERMINAL BLOCKS FOR AVR




Item-2: 32 Pin Euro card connector to the following specification

| Material code | BP9047581369 |
|----------------|---|
| Conductor Size | 0.02-4 mm ² (single core) or 0.02-2.5 mm ² (stranded) |
| Rated Voltage | 250 V AC |
| Rated Current | 4A |
| Configuration | 32 pin (EN60603-2) |
| Material | Plastic, Flame retardant |
| Mounting | suitable for mounting on 35mm din rail |
| Connection | Cage clamp/ Screw terminals |
| Termination | As shown in the schematic diagram below |

| | Name | Signature | Specification no: CEE/14025 |
|-------------------------------------|------------------------------|------------------|-----------------------------|
| Prepared & checked by Revised By | Shalini Sharma Ajay Dhote | Automia Astrites | |
| Approved by | A Mitra | and | Revision no: 01 |
| Date | 24.04.14 | | Date of revision: 12.05.15 |

TECHNICAL SPECIFICATION OF TERMINAL BLOCKS FOR AVR



NOTES TO THE SUPPLIER:

- Price Bid of only those suppliers will be opened who shall comply with the above technical terms.
- Type test certificates should be provided along with the offer.
- The supplier shall in his offer clearly spell out any deviations made on the above specifications.

| | Name | Signature | Specification no: CEE/14025 |
|-------------------------------------|------------------------------|-------------------|-----------------------------|
| Prepared & checked by Revised By | Shalini Sharma Ajay Dhote | Aretini. Astrites | |
| Approved by | A Mitra | mitre | Revision no: 01 |
| Date | 24.04.14 | | Date of revision: 12.05.15 |