

SPECIFICATION

MATERIAL	BRIEF SPECIFICATION	Facilities Required
Steel, DMC and electrical components	Resistor and Capacitor Connected in series and then Moulded in Small DMC Box. Studs are Provided on both ends for Mounting and for Connection	InhouseDMC Moulding facilities. HV Testing facilities up to 5KV, IR Testing facilities, Capability to arrange precision machining,hardness testing