

SPECIFICATION

MATERIAL	BRIEF SPECIFICATION	Facilities Required
COPPER	Current measuring shunt upto 1500 Amp DC, mill volt drop upto 75 milli volt required for traction application.	Facility for nonferrous cating & precise machining. Current source for testing & calibrating the shunt