

SPECIFICATION

MATERIAL	BRIEF SPECIFICATION	Facilities Required
NA	Double Pole latch type DC Contactor rated for 110V DC and 25 Amps .Actuating and trip Control coil is 110V DC.	Experience of manufacturing similar type contactors/relays. Should have in house facilities for assembly and testing of contactors.