

BHARAT HEAVY ELECTRICALS LIMITED, BHOPAL
TRANSFORMER ENGINEERING DEPARTMENT

FORM NO: TRE-2003A

Sht 1 of 1 sheets

ANNEXURE TO INDENT-CUM-ENQUIRY - 240624447

DTD: 19/03/2013

DESCRIPTION OF EQUIPMENT : **FLEXIBLE AIR SEPERATOR (AIR CELL)** for
 1 No. 250 MVA, 420/220/33 kV 3-Ph. ICT
 WORK ORDER NO. : **61084-A-512-01**
 CUSTOMER : **M/s Tenughat Vidyut Nigam Ltd.**

SPECIFICATION OF FLEXIBLE AIR SEPERATOR (AIR CELL)
(FOR 1300 MM DIA X 5800 MM LONG CONSERVATOR)

1. Size: 1.2 mm Thick X 2082 mm Wide X 6582 m Long suitable for conservator size of 1300 mm Dia X 5800 mm long and total oil volume 73200 liters approx.
2. DIMENSIONS :
 W = 2082 mm
 L = 6582 mm
 G = 4300 mm
3. Dimensions W, L, G and other details regarding material and fittings of air cell shall be as per our specification TR20038A (Rev. 07) & TR10150A (Rev. 03) (Already available with the suppliers)
4. QUANTITY : As specified on indent

NOTE:

1. 5 copies of drawing showing the mounting details, description, leaflets & test reports (including type test) should be furnished alongwith the offer for approval.

REV	DATE	ALT CKD	REV-	DATE	ALT- CKD-	REV 00	NAME	SIGN	DATE
						PREP	P. PRAJAPAT	<i>[Signature]</i>	19.03.2013
						CKD	R. K. SINGH	<i>[Signature]</i>	19.03.2013
DWI/TCB/TRE/010									