

**Qualifying criteria for Tangential Beech wood rings**

1. Supplier should have manufacturing capability for tangential beechwood rings to T2R grade of IEC:61061 up to dia 2850mm and thickness 150mm.
2. Annual quantity – 48 nos.  $\pm$  40%
3. Approx. Annual value = 6801600/-
4. Bidder should have experience/ previous POs for supplying the above item to reputed 400 kV class transformer manufacturers.



(Akshay Dave)  
Manager (TRE)