



# PRODUCT STANDARD

SWITCHGEAR ENGINEERING DIVISION

SG12528 rev 00

Page 1 of 4

## SPECIFICATION FOR ALUMINIUM ENCLOSURES FOR GVM36

### 1.0 Introduction

This specification governs the Properties, Manufacturing, Testing, Inspection, Packing and Supply of Aluminum Enclosures for GIS.

### 2.0 Applications:

The Aluminum Enclosure used in GVM36 to provide the SF6 gas insulation to all High Voltage components.

### 3.0 Material specification:-

**Material shall comply as per below standards**

EU	USA	Germany	Japan	Inter
EN	-	DIN,WNr	JIS	ISO
ENAC-AISi7Mg0.3	A356.0	3.2371	AC4CH	AISi7Mg0.3
		G-AISi7Mg		

#### Chemical composition % of grade ENAC-AISi7Mg0.3 (ENAC-42100)

Fe	Si	Mn	Ti	Cu	Mg	Zn	Others
max 0.19	6.5 - 7.5	max 0.1	max 0.25	max 0.05	0.25 - 0.45	max 0.07	each 0.03; total 0.1

#### Mechanical properties of grade ENAC-AISi7Mg0.3 (ENAC-42100)

<b>Tensile strength (MPa)</b>	<b>230</b>
<b>R<sub>p0.2</sub> 0.2% proof strength (MPa)</b>	<b>190</b>
<b>Min. elongation at fracture (%)</b>	<b>2</b>
<b>Brinell hardness (HBW):</b>	<b>75</b>

COPYRIGHT AND CONFIDENTIAL

The information on this document is the property of Bharat Heavy Electricals Limited  
It must not be used directly or indirectly in any way detrimental to interest of Co.

REV.	PRINTS TO:-	APPROVED
ALTD.	PDG 1	SKP
APPD.	SWM 1	<b>PREPARED</b>   <b>ISSUED</b>   <b>DATE</b>
DATE.	C.FILE 1	JAG     24-Apr-19



# PRODUCT STANDARD

SWITCHGEAR ENGINEERING DIVISION

SG12528 rev 00

Page 2 of 4

**COPYRIGHT AND CONFIDENTIAL**

The information on this document is the property of Bharat Heavy Electricals Limited

**It must not be used directly or indirectly in any way detrimental to interest of Co.**

## 4.0 Additional Specifications:

- 4.1 The supplier shall relieve stress of tested component to ensure zero post supply deformation
- 4.2 Supplier shall carry out an application inspection check by assembling enclosures as per drg.no. 35176600598.
- 4.3 Enclosure to be sand / glass bead blasted from inside as well as outside to descale all surface.
- 4.4 Powder coat (>80 Micron) as per standard AA0674124 all external surfaces to shade as specified on Purchase Order after thoroughly cleaning and degreasing of Enclosure in solvent. All Machined Surface shall be masked (avoid using grease, cotton waste).

## 5.0 Routine Tests

- 5.1 The assembly should be cleaned, degreased and prepared for pressure test. The assembly shall be pressure tested for 4 hours at 3 bar.  
Pressure drop shall be recorded and communicated to BHEL.  
In case of pressure drop, a course leak check shall be performed. The leak shall be rectified and the test repeated to satisfaction. Components indicating drop in pressure during this test will not be accepted.
- 5.2 To verify pressure-withstanding capabilities, the assembly shall be Vacuum tested for 30 minutes at -1 bar or below and pressure tested for 15 minutes at 8 bar.
- 5.3 Enclosure assembly shall be tested for Helium Leak test ( $2 \times 10^{-6}$  std. cc/sec).
- 5.4 Powder coating thickness shall be verified as per standard AA0674124.
- 5.5 Radiography test to be conducted on 1<sup>st</sup> sample of lot to be supplied.



# PRODUCT STANDARD

SWITCHGEAR ENGINEERING DIVISION

SG12528 rev 00

Page 3 of 4

**COPYRIGHT AND CONFIDENTIAL**

The information on this document is the property of Bharat Heavy Electricals Limited  
**It must not be used directly or indirectly in any way detrimental to interest of Co.**

## 6.0 QA Plan

QA Plan shall be submitted along with offer & got approved before supply. This shall include tests & measurements on raw material, semi-finished / finished products and details of manufacturing process followed including tools, jigs & fixtures /gauges used at different stages to ensure quality of end product.

## 7.0 Packing

The accepted component shall be packed in wooden boxes with suitable PVC covers on the flanges to prevent transit damages. A thick polyethylene cover shall be used to seal to component from ingress of moisture and water. Adequate quantity of moisture absorbent shall also be placed with the component.

Protective mask should not be removed till final assembly in the manufacturing.

Mask should have stickers ``do not remove before final assembly".

## 8.0 Punching

Punch mark showing Supplier's Name or Monogram / Pressure test / Helium leak test as under at location marked in drawing shall be provided.

Punch mark for enclosure serial no/pressure test/helium leak test / supplier code as below :-

PRESSURE TEST : P

HELIUM LEAK TEST : He

SUPPLIER CODE IN BHEL : XXXXX

PUNCH MARK

XXXXX / P / He / MONTH - YEAR - RUNNING SERIAL

**EXAMPLE S0101 / P / He / 08 – 19 – 019**

Each package shall be legibly and indelibly marked with the following:

- Component name ,Drawing no and Rev no
- BHEL Purchase Order No.
- Batch/Lot No.
- Manufacturer's /Suppliers Name
- Size & Quantity supplied
- Net & Gross Weight



# PRODUCT STANDARD

## SWITCHGEAR ENGINEERING DIVISION

SG12528 rev 00

Page 4 of 4

### 9.0 ACCEPTANCE CRITERIA

Following certificates shall be furnished for acceptance of the component:

- Detailed Dimensional report of 1<sup>st</sup> sample in CMM.
- Dimensional report as per drawing for lot qty.
- Raw Material certificate.
- Pressure drop test as per clause 5.1.
- Pressures withstand test report as per clause 5.2.
- Radiography/ Radioscopy test report as per 5.5 (applicable for 1<sup>st</sup> sample only)
- Stress relieving parameters,
- Powder coating report

A certified copy of above documents shall be sent along with the delivery note.

### 10.0 Guarantee certificate

The equipment shall be warranted for trouble free performance and against any defect in the material for a period of not less than 24 months from the date of supply.

### 11.0 Rework and Rejection:

No rework is allowed. Components not meeting our drawing and specification will be rejected and party has to replace within time. It shall be included in guarantee certificate. In the event of the material proving defective in the course of manufacture; such material shall be rejected notwithstanding any previous certification of satisfactory testing and/or inspection.

**COPYRIGHT AND CONFIDENTIAL**

The information on this document is the property of Bharat Heavy Electricals Limited  
**It must not be used directly or indirectly in any way detrimental to interest of Co.**