


TITLE : FLEXIBLE SEPARATOR FOR ATMOSEAL TYPE CONSERVATOR



W (WIDTH) = $\pi/2$ (CONSERVATOR DIA) + 40

L (LENGTH) = (CONSERVATOR LENGTH - DIA OF CONSERVATOR) + WIDTH OF FLEXIBLE SEPARATOR

G = (CONSERVATOR LENGTH - DIA OF CONSERVATOR - 200)

IT. NO.	STYLE NO. OF FLEXIBLE SEPARATOR	CONSERVATOR SIZE	W	L	G	REMARKS
01		φ800 X LENGTH	1297			CALL DIM. L & G ON INDENT
02	BP9098048172 ST604817	φ1000 X 4400	1810	5010	3200	
03		φ1300 X LENGTH	2082			CALL DIM. L & G ON INDENT
04		φ1600 X LENGTH	2553			CALL DIM. L & G ON INDENT

NOTE:
FLEXIBLE SEPARATOR SHALL MEET THE SPECIFICATION REQUIREMENT OF TR10150A.

RRP
COMP. dng

CONFIDENTIAL AND CONFIDENTIAL
The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED. It must not be used directly or indirectly in any way detrimental to the interest of this Company.

PAGE 1 OF 1

Rev. 5 R.D. 19/08/88	SHEET REAFFIRMED. S.K.S. A.D.	वितरण DISTRIBUTION. TRE/TRM/FTM TRX/TTG/ QC-TCB/QA-TCB/ JHANSI	सं.	स्वीकृत किया APPROVED: sd / MCJ sd / SNA	दियांक DATE 30.12.83
Rev. 8 R.D. 19/08/11	ITEM 04 ADDED. 3/12/83 P.B.C. A.D.			तैयार किया PREPD. D.T.K	जारी किया ISSUED टी आर ई/मानक TRE/STD.