

BHEL

PRODUCT STANDARD. TRANSFORMER

TR 20068 I

OIL FLOW INDICATOR

PAGE 1 OF 1

REF. 7420068 [2.0]

FOLLOWING OIL FLOW INDICATORS HAVE BEEN STYLED AND ARE AVAILABLE IN TRM STOCK.

SL. NO.	STYLE	DRG. NO.	DIAL SIZE	PIPE SIZE	NOM. FLOW LPM	MIN. FLOW LPM	DIRECTION	SWITCH	REMARKS
01	ST604618	TR10050I	100mm	200NB	2700	2500	RIGHT TO LEFT	TWO	SUKRUT MAKE
02	ST604619	TR10050I	100mm	200NB	2700	2500	LEFT TO RIGHT	TWO	SUKRUT MAKE
03	ST604836	TR10050I	100mm	200NB	4500	4300	RIGHT TO LEFT	TWO	SUKRUT MAKE
04	ST604837	TR10050I	100mm	200NB	4500	4300	LEFT TO RIGHT	TWO	SUKRUT MAKE
05	ST605147	TR10050I	100mm	200NB	1800	-	LEFT TO RIGHT	TWO	SUKRUT MAKE
06	ST605148	TR10050I	100mm	200NB	1800	-	RIGHT TO LEFT	TWO	SUKRUT MAKE
07	ST605702	TR10050I	100mm	150NB	1800	-	L TO R	TWO	
08	ST605703	TR10050I	100mm	150NB	1800	-	R TO L	TWO	

NOTE: - ALARM IS TO BE SET AT 80-70 % OF NOM. FLOW.

THIS INFORMATION ON THIS SHEET IS THE PROPERTY OF BHEL. IT MUST NOT BE USED IN ANY WAY DETRIMENTAL TO THE INTERESTS OF THE COMPANY.

TR20068I

REV. 04 DATE 27-3-10 BY P.K.C. CH. AD. MCH.
NO OF SWITCH INCREASED FROM TWO FOR ICM NO 01 TO 06

REV. 03 DATE 26-8-08 BY S.M. SORAL
ITEMS 007 & 008 ADDED

REV. 05 DESTYLE IT. NO. 06
DATE 10-4-08 BY P.K.C. SKG AD.

REVISIONS
REV. 01 13-8-08
REV. 02 07-02-09

DRG. NO WAS TR 20068 & INDR NO. 3207 WAS ON. NOM. FLOW LPM 4500 WAS 4540. MIN. FLOW LPM DELETED. NO. 05 & 06 ADDED.

SHEET REAFFIRMED.

DISTRIBUTION
TRM / TRM / PPM
TCE / TRM /
TTG / CE/PA
ISSUED BY
TRM / STD

APPROVED BY
PREP. A.K. SINHA ROY
ISSUED BY
DATE 28.8.08

TR20068 I
PAGE 1 OF 1